

## DE: Beiblatt Schaltgerät 400V für Pumpstationen *Retrofit L/XL*

### **Technischer Hinweis!**

Der Anlage beiliegende Dokumentation (EBA 010-532) ist zu beachten.

Aufgrund der Einzelanfertigung der Pumpstationen *Retrofit L/XL* sind bei Inbetriebnahme des Schaltgerätes Konfigurationen vorzunehmen. Die zu wählenden Menüpunkte für Ihren vorliegenden Artikel ist, entsprechend der Artikelnummer, der nachfolgenden Dokumentation zu entnehmen.

#### Bei den Pumpen STZ1300 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.1 STZ1300|
```

► Art.-Nr.: 8744010 (Sensortechnik = Pegelsonde)

#### Bei den Pumpen STZ2500 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.2 STZ2500|
```

► Art.-Nr.: 8744012 (Sensortechnik = Pegelsonde)

#### Bei den Pumpen STZ3700 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.3 STZ3700|
```

► Art.-Nr.: 8744014 (Sensortechnik = Pegelsonde)

#### Bei den Pumpen GTF1600 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.11 GTF1600/GTK1300|
```

► Art.-Nr.: 8744022 (Sensortechnik = Pegelsonde)

#### Bei den Pumpen GTF2600 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.12 GTF2600/GTK2600|
```

► Art.-Nr.: 8744024 (Sensortechnik = Pegelsonde)

#### Bei den Pumpen GTF4000 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.13 GTF4000/GTK3700|
```

► Art.-Nr.: 8744026 (Sensortechnik = Pegelsonde)

#### Bei den Pumpen GTK1300 bitte folgende Menüpunkte am Schaltgerät einstellen:

```
|3.4. Anlagen-Konfiguration|  
=> |3.5.2 Pumpstationen|  
=> |3.6.1 Aquapump XL|  
=> |3.7.11 GTF1600/GTK1300|
```

► Art.-Nr.: 8744030 (Sensortechnik = Pegelsonde)

Bei den Pumpen GTK2600 bitte folgende Menüpunkte am Schaltgerät einstellen:

|3.4. Anlagen-Konfiguration|

=> |3.5.2 Pumpstationen|

=> |3.6.1 Aquapump XL|

=> |3.7.12 GTF2600/GTK2600|

► Art.-Nr.: 8744032 (Sensortechnik = Pegelsonde)

Bei den Pumpen GTK3700 bitte folgende Menüpunkte am Schaltgerät einstellen:

|3.4. Anlagen-Konfiguration|

=> |3.5.2 Pumpstationen|

=> |3.6.1 Aquapump XL|

=> |3.7.13 GTF4000/GTK3700|

► Art.-Nr.: 8744034 (Sensortechnik = Pegelsonde)

## EN: Supplement for the 400V control unit for pumping stations *Retrofit L/XL*

### Technical note!

Observe the documentation (EBA 010-532) enclosed with the system.

Due to the individual production of the pumping stations *Retrofit L/XL*, configurations must be defined when commissioning the control unit. The menu items to be selected for your article can be found in the following documentation according to the article number.

#### Please set the following menu items on the control unit for the pumps STZ1300:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.1 STZ1300|
```

► Art. no. 8744010 (sensor technology = level probe)

#### Please set the following menu items on the control unit for the pumps STZ2500:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.2 STZ2500|
```

► Art. no. 8744012 (sensor technology = level probe)

#### Please set the following menu items on the control unit for the pumps STZ3700:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.3 STZ3700|
```

► Art. no. 8744014 (sensor technology = level probe)

#### Please set the following menu items on the control unit for the pumps GTF1600:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.11 GTF1600/GTK1300|
```

► Art. no. 8744022 (sensor technology = level probe)

#### Please set the following menu items on the control unit for the pumps GTF2600:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.12 GTF2600/GTK2600|
```

► Art. no. 8744024 (sensor technology = level probe)

#### Please set the following menu items on the control unit for the pumps GTF4000:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.13 GTF4000/GTK3700|
```

► Art. no. 8744026 (sensor technology = level probe)

#### Please set the following menu items on the control unit for the pumps GTF1300:

```
|3.4. System configuration|  
=> |3.5.2 Pumping stations|  
=> |3.6.1 Aquapump XL|  
=> |3.7.11 GTF1600/GTK1300|
```

► Art. no. 8744030 (sensor technology = level probe)

Please set the following menu items on the control unit for the pumps GTK2600:

|3.4. System configuration|

=> |3.5.2 Pumping stations|

=> |3.6.1 Aquapump XL|

=> |3.7.12 GTF2600/GTK2600|

► Art. no. 8744032 (sensor technology = level probe)

Please set the following menu items on the control unit for the pumps GTK3700:

|3.4. System configuration|

=> |3.5.2 Pumping stations|

=> |3.6.1 Aquapump XL|

=> |3.7.13 GTF4000/GTK3700|

► Art. no. 8744034 (sensor technology = level probe)